

Pression de saturation de H2O en millibars en fonction de la température

l'intervalle des mesures psychrométriques : 0 à 50 °C

	0	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0	6.108	6.125	6.197	6.241	6.287	6.332	6.378	6.424	6.471	6.518
1	6.566	6.613	6.661	6.711	6.757	6.806	6.855	6.904	6.953	7.003
2	7.054	7.104	7.155	7.206	7.258	7.31	7.362	7.415	7.458	7.521
3	7.575	7.629	7.683	7.736	7.791	7.847	7.902	7.958	8.015	8.072
4	8.129	8.186	8.243	8.301	8.36	8.419	8.478	8.538	8.597	8.658
5	8.719	8.78	8.842	8.903	8.965	9.028	9.092	9.155	9.218	9.283
6	9.348	9.412	9.477	9.543	9.609	9.675	9.742	9.809	9.876	9.944
7	10.013	10.081	10.15	10.22	10.29	10.361	10.431	10.503	10.575	10.647
8	10.721	10.793	10.867	10.941	11.016	11.09	11.166	11.242	11.319	11.395
9	11.473	11.55	11.629	11.707	11.786	11.866	11.945	12.026	12.107	12.189
10	12.271	12.353	12.436	12.519	12.604	12.688	12.773	12.858	12.944	13.03
11	13.117	13.205	13.293	13.381	13.47	13.56	13.65	13.74	13.831	13.923
12	14.016	14.108	14.201	14.295	14.389	14.484	14.58	14.676	14.772	14.869
13	14.967	15.064	15.163	15.263	15.362	15.463	15.564	15.663	15.767	15.87
14	15.974	16.078	16.182	16.287	16.393	15.5	16.607	16.714	16.822	16.931
15	17.04	17.151	17.262	17.372	17.484	17.597	17.71	17.824	17.938	18.054
16	18.17	18.285	18.403	18.52	18.639	18.758	18.878	18.998	19.12	19.242
17	19.364	19.486	19.61	19.734	19.859	19.984	20.11	20.238	20.365	20.493
18	20.623	20.753	20.883	21.014	21.147	21.28	21.414	21.548	21.683	21.82
19	21.957	22.094	22.233	22.372	22.512	22.653	22.795	22.937	23.08	23.224
20	23.369	23.514	23.66	23.808	23.956	24.105	24.254	24.404	24.555	24.707
21	24.86	25.013	25.167	25.322	25.478	25.635	25.791	25.949	26.108	26.268
22	26.429	26.59	26.751	26.913	27.077	27.241	27.406	27.572	27.739	27.903
23	28.076	28.246	28.418	28.59	28.763	28.937	29.112	29.288	29.465	29.643
24	29.822	30.001	30.183	30.365	30.548	30.732	30.917	31.103	31.289	31.476
25	31.665	31.854	32.044	32.235	32.427	32.619	32.813	33.007	33.203	33.399
26	33.597	33.796	33.996	34.198	34.4	34.603	34.808	35.013	35.22	35.428
27	35.637	35.848	36.06	36.274	36.488	36.703	36.919	37.137	37.355	37.574
28	37.795	38.016	38.237	38.459	38.681	38.904	39.129	39.355	39.583	39.811
29	40.041	40.271	40.504	40.739	40.974	41.21	41.448	41.689	41.93	42.171
30	42.414	42.658	42.904	43.151	43.399	43.648	43.899	44.151	44.405	44.659
31	44.914	45.17	45.427	45.686	45.946	46.207	46.47	46.733	46.998	47.265
32	47.533	47.802	48.073	48.345	48.618	48.893	49.17	49.447	49.726	50.006
33	50.288	50.571	50.855	51.141	51.428	51.716	52.006	52.298	52.591	52.885
34	53.181	53.479	53.778	54.078	54.38	54.683	54.988	55.294	55.602	55.911
35	56.221	56.532	56.844	57.158	57.474	57.791	58.109	58.429	58.751	59.074
36	59.399	59.725	60.033	60.383	60.715	61.049	61.385	61.722	62.061	62.401
37	62.743	63.086	63.43	63.776	64.124	64.473	64.824	65.176	65.53	65.886
38	66.244	66.603	66.964	67.328	67.69	68.056	68.423	68.794	69.164	69.537
39	69.912	70.286	70.663	71.042	71.423	71.806	72.19	72.576	72.964	73.354
40	73.746	74.14	74.536	74.935	75.336	75.738	76.142	76.548	76.956	77.365
41	77.776	78.189	78.604	79.019	79.437	79.857	80.278	80.701	81.126	81.553
42	81.982	82.413	82.846	83.283	83.72	84.16	84.601	85.044	85.489	85.936
43	86.386	86.837	87.291	87.747	88.205	88.665	89.127	89.591	90.056	90.525
44	90.996	91.469	91.944	92.42	92.9	93.382	93.865	94.351	94.838	95.328
45	95.82	96.314	96.809	97.306	97.807	98.308	98.813	99.319	99.828	100.338
46	100.852	101.367	101.885	102.406	102.929	103.455	103.983	104.512	105.045	105.58
47	106.117	106.657	107.199	107.743	108.29	108.839	109.39	109.943	110.499	111.058
48	111.619	112.182	112.747	113.314	113.884	114.456	115.031	115.609	116.189	116.771
49	117.356	117.944	118.534	119.126	119.722	120.32	120.921	121.524	122.129	122.737